

Large Signal Modeling and Characterization of Power Transformers with Magnetic Core

ANALOG DEVICES

Xing Xing, Flow Zhao, Baoxing Chen, Analog Devices, Inc., Wilmington, MA, USA, 01887

Abstract

In order to fully define integrated power transformers with magnetic cores, it is essential to not only characterize the small signal properties but also the large signal characterizations because the power delivery capability is limited by the saturation of the core which is a nonlinear behavior. In this work, a method was implemented to characterize the saturation non-linear current and behavior of the transformers. In addition, methodology developed predict saturation accurately behavior.

Isolated Power Solutions



Discrete solutions optocouplers external transformers

- Large
- Custom designs
- Poor Reliability


Proprietary *iso*Power® integrates data & power

- Data isolation
- DC/DC converter
- All-in-one package


From Air Core to Magnetic Core Transformer

Magnetic core solenoid transformers have

- High efficiency
- Low operating frequency → low EMI
- Non-linear behavior when saturating









2nd Gen of isoPower® with magnetic core power

DC/DC Converter Design Goals	
Architecture	Fly-back DC/DC Converter
Input Voltage	5 Volt
Output Voltage	5 Volt
Frequency	20 MHz
Power	200mW
Inductance	320nH
Q @20MHz	9.4
Peak Current	0.75 Amp

Small Signal Characterization




Large Signal Characterization



- Apply a square wave voltage across the inductor.
- Monitor the current through the inductor.
- Slew rate of the voltage signal has to be controlled.
- Duty cycle of the square wave has to be controlled.

Large Signal Modeling



Conclusion

- The VNA tested S-parameter models of the transformers are only suitable for small signal circuit simulation, i.e. data transmission.
- For power applications, the large signal characterization and models of the transformers need to
- The magnetic core transformers are able to deliver higher power with higher efficiency but will saturate at a point.
- The saturation current could be tested by monitoring the current when a square wave voltage is
- By characterizing the magnetic core, the non-linear large signal model of the transformer could be generated, and the saturation current could be predicted.

References

[1] Xing et al, "High-Bandwidth Low-Insertion Loss Solenoid Transformers Using FeCoB Multilayers", IEEE Transactions on Power Electronics, Vol 28, Issue 9, (2013).

[2] Xing et al, "RF Magnetic Properties of FeCoB/Al₂O₃/FeCoB Structure With Varied Al₂O₃ **Thickness**

Corresponding author email: xing.xing@analog,com